

Letter issued under the responsibility of



www.nemko.com

**Nemko USA, Inc.**

2210 Faraday Ave, Suite 150, Carlsbad, CA,  
92008

Phone (769) 444-3500, Fax (760) 444-3005

**LETTER OF CONFORMITY**

**Ref. No. 403062-ATX-1, 403062-ATX-2**

Issue Date:

August 31, 2020

Product

EtherNet/IP to Profibus PA Link Module

Name and address of the manufacturer

Aparian, Inc.  
24 Twain St., Irvine, CA 92617 United States

Trade mark (if any).



Model/Type Ref.

A-PAL/B

Required marking:



II 3 G Ex nA IIC T4 X Gc  
-20 °C ≤ Ta ≤ +70 °C

A sample of the product has been tested and found to be in conformity with the current standard, (number and edition):

IEC 60079-0:2011, 6<sup>th</sup> Edition and IEC 60079-15:2010, 4<sup>th</sup> Edition

Summary of the test results:

Based on the findings of the assessment of the equipment to the requirements of IEC 60079-0:2011 and IEC 60079-15:2010, reports provided to manufacturer, and the results of the type testing, the product was found to meet all of the applicable requirements of the standards as described in the assessment. Refer to Nemko test reports Ref. No. 403062-ATX-1 and 403062-ATX-2.

Special Conditions for Use:

Product is intended to be installed in an external enclosure that provides a minimum ingress protection of IP54.

This "Letter of compliance" is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard.

This "Letter of compliance" is not a certificate and may not be used as one.

Note that although IECEX reports were provided as supporting documents to this report, the reports were not issued by an IECEX Testing Laboratory or Certification Body, and IECEX certification is not implied.

Issued By:

A handwritten signature in black ink that reads "Luis Gonzalez".

Luis Gonzalez  
Lab Supervisor