

CERTIFICATE OF COMPLIANCE

Certificate Number E183151
Report Reference E183151-20100811
Date 2021-April-23

Issued to: PROSOFT TECHNOLOGY INC
9201 Camino Media, Suite 200
Bakersfield CA, 93311 US

**This is to certify that
representative samples of**

PROGRAMMABLE CONTROLLERS FOR USE IN
HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

Standard No. UL 121201, Nonincendive Electrical
Equipment for Use in Class I and II, Division 2 and Class III,
Divisions 1 and 2 Hazardous (Classified) Locations

Standard No. CSA C22.2 No. 213-17, Nonincendive
Electrical Equipment for Use in Class I and II, Division 2
and Class III, Divisions 1 and 2 Hazardous (Classified)
Locations

Standard No. UL 508, Standard for Industrial Control
Equipment


Standard No. CSA C22.2 No. 142-M1987, Process Control
Equipment

Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.



Bruce Mahrenholz, Director North American Certification Program

UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

CERTIFICATE OF COMPLIANCE

Certificate Number E183151
Report Reference E183151-20100811
Date 2021-April-23

Look for the UL Certification Mark on the product.

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

USL, CNL – Programmable Logic Controllers for use in Class I, Division 2, Groups A, B, C and D Hazardous Locations.

Communication module Models:


MVI56E; followed by –GSC, -MCM, -MCMR, MCMXT, -MNET, -MNETXT, MNETC, MNETCXT, MNETCR, MNETR, FLN, SIE, DNPNET, 61850S, GSCXT, LDM, AFC, GEC or -SMGC.

MVI56; followed by –HART or –PDPMV1.

MVI46; followed by –HART or –PDPMV1.

*ILX56-MM.

Devices may be marked with suffix “-CC” indicating conformal coating



Bruce Mahrenholz, Director North American Certification Program

UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>