

Letter issued under the responsibility of



www.nemko.com

Nemko USA, Inc. (Austin)

1601 N. A.W. Grimes Blvd, Round Rock,
Texas 78665
Phone (512) 244-3371

LETTER OF CONFORMITY

Ref. No. REP0069950-ATX

Issue Date:

2025-01-09

Product

Communication module intended for use in industrial control applications. Devices are DC powered and use a variety of communications protocols. See report for further descriptions.

Name and address of the manufacturer

ProSoft Technology, Inc.
9201 Camino Media #200, Bakersfield, CA 93311, United States

Trade mark (if any).



Model/Type Ref.

ELX3.

Required marking:



II 3 G Ex ec IIC T4 X Gc
-40 °C ≤ Ta ≤ 70 °C

A sample of the product has been tested and found to be in conformity with the current standard, (number and edition):

EN IEC 60079-0:2018

EN 60079-7:2015+A1:2017

Summary of the test results:

Based on the findings of the assessment of the equipment to the requirements of EN IEC 60079-0:2018 and EN 60079-7:2015+A1:2017, reports provided to manufacturer, and the results of the type testing, the product was found to meet all of the applicable requirements of the standards as described in the assessment. Refer to Nemko test report Ref. No. REP0069950-ATX.

Specific Conditions for Use:

-Install the device according to EN 60664-1 in an environment not exceeding degree of pollution 2.
-Install the device in a suitable enclosure providing a degree of protection of at least IP54 according to EN 60079-0, taking into account the ambient conditions under which the equipment will be used.

This "Letter of conformity" is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard.

This "Letter of conformity" is not a certificate and may not be used as one.

Note that although IECEX and ATEX reports were provided as supporting documents to this report, ATEX and IECEX certification is not implied.

Issued By:

A handwritten signature in black ink, appearing to read "Matthew Brock".

Matthew Brock

Explosion Protection Sr. Engineer