

# CERTIFICATE OF COMPLIANCE

**Certificate Number** E213912  
**Report Reference** E213912-20210816  
**Date** 2021-August-19

**Issued to:** PROSOFT TECHNOLOGY INC  
9201 Camino Media, Suite 200  
Bakersfield CA, 93311 US

**This is to certify that  
representative samples of**

TELEMETERING EQUIPMENT FOR USE IN HAZARDOUS  
LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

UL 121201 and CAN/CSA C22.2 No. 213-17, Nonincendive  
Electrical Equipment for Use in Class I and II, Division 2  
and Class III, Divisions 1 and 2 Hazardous (Classified)  
Locations  
UL 61010-1 and CAN/CSA No. 61010-1-12, Safety  
Requirements For Electrical Equipment For Measurement,  
Control, And Laboratory Use Part 1: General Requirements  
UL 61010-2-201 and CSA C22.2 NO. 61010-2-201:18,  
Safety Requirements For Electrical Equipment For  
Measurement, Control And Laboratory Use - Part 2-201:  
Particular Requirements For Control Equipment


**Additional Information:**

See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up  
Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's  
Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>




# CERTIFICATE OF COMPLIANCE

**Certificate Number** E213912  
**Report Reference** E213912-20210816  
**Date** 2021-August-19

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Edge Gateway Models ELX1, ELX1-LTE-A, ELX1-W4, ELX1-LTE-W4, ELX1-SER4 and ELX1-LTE-W4-SER4-A. May be marked with suffix -CC for conformal coating.

Advanced Edge Gateway Models ELX3, ELX3-LTE-A, ELX3-LTE-W4 and ELX3-SER4. May be marked with suffix -CC for conformal coating



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

