

Letter issued under the responsibility of



www.nemko.com

Nemko USA, Inc.

2210 Faraday Ave, Suite 150, Carlsbad, CA, 92008

Phone (769) 444-3500, Fax (760) 444-3005

LETTER OF CONFORMITY

Ref. No. 381583-2

Issue Date: 26 September, 2019
Automated Flow Computer
Product Devices are DC powered and use a variety of communications protocols. See individual reports for further descriptions.

Name and address of the manufacturer ProSoft Technology, Inc.
9201 Camino Media #200, Bakersfield, CA, 93311, United States

Trade mark (if any).



Model/Type Ref. MVI56E-FLN, **MVI56E-GEC**, MVI56E-GSC, MVI56E-MCM, MVI56E-MCMR, MVI56E-MNET, MVI56E-MNETC, MVI56E-MNETCR, MVI56E-MNETR, MVI56E-DNPNET, MVI56E-61850S, MVI56E-LDM, MVI56E-AFC, MVI56E-SIE, ILX56-PBS, ILX56-PBM
(rated for 60°C operation)
MVI56E-GSCXT, MVI56E-MCMXT, MVI56E-MNETXT
(rated for 70°C operation)

Required marking: II 3 G Ex nA IIC T5 X or II 3 G Ex nA IIC T5 X 0
°C ≤ Ta ≤ 60 °C -25 °C ≤ Ta ≤ 70 °C

A sample of the product has been tested and found to be in conformity with the current standard, (number and edition): IEC 60079-0:2017, 7th Edition and IEC 60079-15:2017, 5th Edition

Summary of the test results: The industrial computer device equipment fulfils the requirements of explosion protection for Equipment Group II and Category 3 G in the type of protection non-sparking and/or energy limited apparatus for gases of Explosion Group II

Special Conditions for Use: Product is intended to be installed in an external enclosure that provides a minimum ingress protection of IP65, as described in Section 6.6 of EN/IEC 60079-15, unless the device enclosure inclusively meets these requirements.

This "Letter of compliance" is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard.

This "Letter of compliance" is not a certificate and may not be used as one.

Note that although IECEX reports were provided as supporting documents to this report, the reports were not issued by an IECEX Testing Laboratory or Certification Body, and IECEX certification is not implied.

Issued By:

Jose Elias
Safety Lab Manager